

## **Compliance Statement**

No. 2016-074

Data communication cords, Category 6

Company Feller AG Bergstrasse 70 8810 Horgen Switzerland Product description Unscreened Category 6 RJ45 cords (equipment, patch, and work area) characterised up to 250 MHz **Product identification** 1180-PCxxx.C6U (xxx denotes length, such as 050 for 0.5 meter and up to 1000 for 10 meters) Generic cabling and cabling components standard - Category 6 balanced cord requirements ISO/IEC 11801:2011 (Ed. 2.2) • EN 50173-1:2011 EN 50173-2:2007 including amendment A1:2010 • ANSI/TIA-568-C.2:2009 IEC 61935-2:2010 (Ed. 3.0) (transmission requirements)

Technical report DELTA-T212113, DANAK-19/16075 EC Cabling product ID 5967

**CS valid until** 25 January 2017

This product has been tested by DELTA EC Cabling Group and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a sample test of the product once a year.

Hørsholm, 25 January 2016

Lindoka Pedma

Lars Lindskov Pederser Test Manager

**DELTA** Venlighedsvej 4 2970 Hørsholm Denmark

Tel. +45 72 19 40 00 Fax +45 72 19 40 01 www.madebydelta.com/cable

- Vicut

Claude Videt Project Manager

